

Ohio Department of Transportation

Prebid Questions

Project No. 100035

Sale Date - 1/28/2010

Question Submitted: 1/13/2010

Question Number: 1

Are the logs from the test borings available for review? If so, please publish them on the FTP site. Thank you.

Boring logs are only available for B-7, 8, and 9. They have been placed in the Plans Directory under MEG-79830-borings.

Question Submitted: 1/7/2010

Question Number: 2

Will the brown sandstone that is native to the project area meet the specifications for the dump rock fill?

The contractor must provide dumped rock fill that meets CMS 703.19-B.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.