

# Ohio Department of Transportation

## Prebid Questions

Project No. 090083

Sale Date - 2/25/2009

Question Submitted: 2/12/2009

Question Number: 1

In reference to the sanitary sewer along SR 41, the soils report indicates sandy silts with the presence of water in this area. Can we dig test holes to verify ground conditions? If acceptable, please indicate the acceptable locations.

**The contractor can dig test holes after he obtains a permit through the District 7 Permit Section (<http://www.dot.state.oh.us/districts/D07/Pages/RightofWayUsePermits.aspx>). He will need to prepare a sketch indicating where the test holes will be as ODOT will not tell him where to dig. He must place an OUPS locate call and avoid impacting any existing utilities.**

Question Submitted: 2/12/2009

Question Number: 2

In reference to bid item #71 I wanted to verify that the correct ODOT spec number was referenced: 706.08 vitrified clay pipe?

**706.08 vitrified clay pipe is correct**

Question Submitted: 2/12/2009

Question Number: 3

Can you make the cross section report available in text format so it is downloadable in AGTECK.

**No, this information is now available**

Question Submitted: 2/12/2009

Question Number: 4

Could you please post the design files for the Miami County S.R. 41-12.64 project.

**<ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/MIA-77454/>**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.