

Ohio Department of Transportation Prebid Questions

Project No. 060317

Sale Date - 7/12/2006

Question Submitted: 7/5/2006

Question Number: 1

Part 1 of the project calls for 2.50 inches of Type 1 Intermediate Course. With this thickness, should the mix be Type 2?

No, please bid with Type 1

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.