

Ohio Department of Transportation

Prebid Questions

Project No. 070320

Sale Date - 6/13/2007

Question Submitted: 6/4/2007

Question Number: 1

I see no description of the existing beams or the grade for the steel in ref. #3. Please advise the grade of material to use for the web plates, crossframe angles, and the masonry plate retainers. Thank You.

A-709 Grade 50

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.