

Ohio Department of Transportation

Prebid Questions

Project No. 090257

Sale Date - 5/13/2009

Question Submitted: 4/27/2009

Question Number: 1

Reference 0003 full depth pavement removal and rigid replacement, Class MS, requires by specification a 24 hour cure and a beam break of 400 lbs. Page 6 of the plans indicates the Contractor shall only be permitted to have lane closures between the hours of 8:00pm to 7:00am. Is the designer's intent to use FS concrete with a 4 hour cure or will the lane closure time be extended to allow for the 24 hour cure of MS concrete. Please advise.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.