

Ohio Department of Transportation

Prebid Questions

Project No. 085011

Sale Date - 9/3/2008

Question Submitted: 8/28/2008

Question Number: 1

This question has to do with sheet 5/11 in the contract drawings. The details in this drawing clearly show two sections of deck and parapet that have to be removed and then later replaced after the new section of beam is installed. There seem to be no pay items for this work, though. Line item 3 Dowel Holes with Nonshrink, Nonmetallic Grout with a quantity of 60 each is in the pay items, but there are no items for the reinforcing bars or concrete. There also is no item for the removal of the concrete. Can you please supply a new list of pay items which include these three things?

The removal and replacement of reinforcing steel and concrete deck including HMWM sealer are included on Item 513 structural steel members, level 3, as per plan. See note on sheet 2/11.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.