

Ohio Department of Transportation

Prebid Questions

Project No. 091128

Sale Date - 12/17/2009

Question Submitted: 12/10/2009

Question Number: 1

Under Traffic Control, is Ref 0013 642 Crosswalk Line in fact 642 or should it be 644 Crosswalk Line?

This item is not changing and will remain the same 642 not 644.

Question Submitted: 12/13/2009

Question Number: 2

Is it ODOT's intention not to require ARRA signs on this project even though it is a stimulus project?

This project was given a waiver for the signs as there is no public R/W available to erect them and they would be a sight distance hazard in this urban setting.

Question Submitted: 12/9/2009

Question Number: 3

This is concerning Item 008 421 Microsurfacing, Surface Course. The project consists of a two lane street that has numerous intersections with other streets and drives for businesses that will require stoppages in placing the microsurfacing. This breaks the total square yardage into smaller segments of less than 15,500 SY. On similar type projects in the past, ODOT has allowed for truck mounted machines to apply the microsurfacing. Will ODOT allow truck mounted machines for this project?

ODOT will allow truck mounted machines on this project.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.