

# Ohio Department of Transportation

## Prebid Questions

Project No. 100164

Sale Date - 4/1/2010

Question Submitted: 3/23/2010

Question Number: 1

On contract drawing 4/12, there are three plan notes, Item 513 - Structural Steel Members, Level UF, as per plan; Item 202 - Portions of Structures Removed, as per plan (Main Members); and Item 202 - Portions of Structures Removed, as per plan (Secondary Members). There are no pay items for the work described in these plan notes. Please clarify.

**These notes have been removed by addendum 1.**

Question Submitted: 3/23/2010

Question Number: 2

In the note for Item 513 - Structural Steel Misc.: Repair of Damaged Members on contract drawing 4/12 it states, "Repair damaged areas as determined by field inspection according to supplemental specification 849.12, damage assessment." According to supplemental specification 849, the damage assessment must happen before any heat straightening occurs. If cracks occur in the structural steel during the straightening of damaged members after the damage assessment has been performed, will this work be paid for on a force account basis, or should we put the pricing for all of these possible repairs under Structural Steel Misc.: Repair of Damaged Members?

**We have added 0.1 Hours of Item 849, Repairing Damaged Members by Grinding for each linear foot of damaged beam, for a total of 1.1 Hours.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.