

Ohio Department of Transportation

Prebid Questions

Project No. 070193

Sale Date - 4/18/2007

Question Submitted:

Question Number: 1

Do you have any suggestions about the location with similar decorative base for the pole?

Downtown, City of Zanesville along Main Street has similar installations in place. See sample pictures in the below link. <ftp://ftp.dot.state.oh.us/pub/Districts/D05/Projects/Mus/77034/>

Question Submitted: 4/10/2007

Question Number: 2

Drive details call for 2A curb on most of drives should there be a bid item for 2A curb?

The type 2-A curb for the drives is to be poured integral, and is included in the cost, to the drive approaches with 452 Items. See details on sheet 41 and 47

Question Submitted: 4/11/2007

Question Number: 3

B/R#'s 127.AA2, 128. AA2 & 129. AA2 The plans call for 8 Flute. 1. Would 16 Flute be acceptable?2. Could we have a more detailed picture of the decorative base?

A1: Yes. 16 flutes on the pole would be acceptable. A2. District feels that enough information is included in the plans for preparing the bids.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.