

Ohio Department of Transportation Prebid Questions

Project No. 050085

Sale Date - 2/2/2005

Question Submitted: 1/5/2005

Question Number: 1

On sheet 4 and on sheet 16 of the plans for these covered bridges lists the hardware schedule. The bolts are to be A307. The question is: Are the bolts to be roll thread bolts or cut thread bolts? ASTM says they are equal, however some designers (Richland Engineering in this case) Assume cut thread, which are about double the cost of rolled thread bolts. Please Advise.

The bidding documents permit both cut and rolled bolts. The contractor may choose.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.