

Ohio Department of Transportation

Prebid Questions

Project No. 090528

Sale Date - 12/4/2009

Question Submitted: 11/18/2009

Question Number: 1

Structures OTT 590-0811 and OTT 590-0833 both call for full depth replacement of the pavement 50' off the end of each approach slab. Under contract 088021, the pavement was replaced full depth at 100' off the end of each approach slab. Is it the intent to leave 50' of old pavement in place? Will the Department consider extending the full depth replacement to meet the work completed on 088021 in the fall of 2008?

The limits were revised in addenda 1.

Question Submitted: 11/20/2009

Question Number: 2

We beleive there are 3 bid items omit for Bridge No. OTT-590-0793. 1. Item 848 Surface Prep using Hydrodemolition, 2. Item 848 Micro-silica (Variable Thickness) Material Only and 3. Item 848 Existing Conc. Overlay Removed, APP..The above items are included in Bridge No. OTT-590-0908.

The quantities have been revised in addenda 1.

Question Submitted: 11/24/2009

Question Number: 3

1)The plans do not callout an 848 Supplemental Spec for bridge deck overlay with hydro-demolition, will one be added ? 2) In the past hydro water was run through aggregate dams to remove solids then allowed to follow natural drainage, will this be allowed or will hydro water have to be handled in a different manor ?

Please refer to addenda 1 and note sheet revisions for plan sheets 29/47 and 39/47.

Question Submitted: 12/1/2009

Question Number: 4

In our pre-bid question dated 11/24/09 we noted the plans did not have an 848 Supplemental Spec called out on the cover sheet. Addendum No. 1 did not add an 848 Spec with effective date to the plans, we believe a spec is required for bidding, will one be added ?

See Addendum No. 2, adding the following supplemental specification to the title sheet.SS 848 dated 10/16/2009

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.