

Ohio Department of Transportation

Prebid Questions

Project No. 101061

Sale Date - 4/8/2010

Question Submitted: 3/26/2010

Question Number: 1

Item #3 Pavement Removed - The CADD generated bid quantity appears to be overstated. Would ODOT please verify this quantity and advise of any corrections?

The quantity has been verified and is correct as shown.

Question Submitted: 4/1/2010

Question Number: 2

Contract Line Item 54 - Partial Depth Pavement Repair is referenced on page 12 / 65 under the "Designated Local Detour Route" heading. The depth of the repair has not been provided. What is the proposed depth for this item?

The depth of this item will be determined by the Engineer based on field conditions in order to maintain and subsequently restore the designated local detour route.

Question Submitted: 4/2/2010

Question Number: 3

In response to ODOT's answer regarding the pavement repair under the "Designated Local Detour Route" would ODOT provide a depth for bidding purposes?

Partial Depth Pavement Repair depth shall be as directed by the Engineer. An estimated average depth of 3" may be used for estimating purposes only.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.