

Ohio Department of Transportation

Prebid Questions

Project No. 100421

Sale Date - 6/24/2010

Question Submitted: 6/18/2010

Question Number: 1

for the surface prep of the parapet, is required to remove 100% of the existing coating or can we brush blast it as well?

The concrete parapets shall follow the surface preparations as stated in 512.03 of the CMS.

Question Submitted: 6/9/2010

Question Number: 2

Per CMS 512.03(F), following the surface prep the surface of the concrete must feel and look like 100 grit sandpaper or coarser. Will this also be true for the precast beam portion of the epoxy-urethane sealing?

The precast concrete beams shall follow the surface preparations as stated in 512.03 of the C&MS.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.