

Ohio Department of Transportation

Prebid Questions

Project No. 090156

Sale Date - 3/4/2009

Question Submitted: 1/14/2009

Question Number: 1

Part 1 - Page 52 - Box Culvert Under reinforcing steel it says "all reinforcing shall be epoxy coated." I am taking this as all the steel in the box culvert needs to be epoxy coated. But I can't find anything on the box culvert for Part 2 of the project. So is the box for Part 2 just black steel?

ANS: The box culvert, Item 603 - 14'X6'CONDUIT, TYPE A, 706.05, AS PER PLAN, is to be constructed as per CMS Item 603 except as shown on sheet 56/62. The "all reinforcing shall be epoxy coated." refers to the steel in the headwalls. ANS: YES.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.