

Ohio Department of Transportation Prebid Questions

Project No. 050462

Sale Date - 9/7/2005

Question Submitted: 8/6/2005

Question Number: 1

plan sheet 6/6 shows vertical extensions 1-1/2" wide on the bridge and 2" wide on the backwall. there is no room to put 3/8 fillet welds on both sides of the 1-1/2" extrusion. also our previous projects have all used 1/4 fillet welds for vertical extensions and extrusions. please explain the intent. we wish to avoid force account work. thank you.

A 1/4" fillet weld is sufficient for extensions and extrusions.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.