

Ohio Department of Transportation

Prebid Questions

Project No. 100026

Sale Date - 1/14/2010

Question Submitted: 12/30/2009

Question Number: 1

REF# 25,29,35 are Polymer Modified Asphalt Expansion Joints But the bridges have no asphalt planning or asphalt quantities. Are the joints all in asphalt or is half in concrete that will be milled out?

The Polymer Modified Asphalt Expansion Joints are to be installed in the asphalt adjacent to the bridge deck. No milling of concrete is required.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.