

Ohio Department of Transportation

Prebid Questions

Project No. 080389

Sale Date - 6/6/2008

Question Submitted: 5/21/2008

Question Number: 1

Note for Item 513 on sheet 2/11 (54/76) says "Structural Steel Members Galvanized in accordance with the included proposal note (AN-8)." This proposal note does not appear in the proposal, nor does it appear in the plans, nor does it appear on ODOT's website. Please advise how I might obtain a copy of this proposal note. Thank You.

Question Submitted: 5/28/2008

Question Number: 2

Will SIP forms be allowed on this project?

No.

Question Submitted: 5/30/2008

Question Number: 3

Addendum #2 addresses silty soils and modification using chemically stabized embankment.Q. Should a bid item be added for Chemically Stabilized Emb?

No bid item for Chemically Stabilized Embankment will be added. Pay Item 203 Embankment, As Per Plan includes the chemical stabilization of the lower 5 feet of the embankment. The Item 203 Embankment, As Per Plan note on sheet 4A and addendum #2 instructs the contractor to include chemical stabilization in the Item 203 for payment.

Question Submitted: 6/2/2008

Question Number: 4

Bid item 21 S&M of Vegetative Filter StripWhere do we find the seed mix that is required for this Seed & Mulch of "Vegetative Filter Strip" ?Please clarify.Thank you,

The seed mix shall be that which conforms to Class/Type 7 - Temporary Erosion Control Mixture as listed in Table 659.09-1 of the 2005 CMS.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.