

Ohio Department of Transportation

Prebid Questions

Project No. 070254

Sale Date - 5/16/2007

Question Submitted: 5/10/2007

Question Number: 1

Item 19 Asphalt Concrete Intermediate, Type 2 specs PG64-28 liquid. Is this correct? It is such a small quantity, which makes it difficult to produce.

Question Submitted: 5/14/2007

Question Number: 2

Could you provide further clarification on the biditem for Embankment as noted on sheet 4/27? It is unclear from the plans where the embankment is to be placed or if this item is even needed for this project.

Estimated quantity of embankment was provided for placement on graded shoulders and slopes for the erosion control at bridge in accordance with Standard Drawing DM-4.1. This work should occur between the removal of the existing guardrail and the placement of the proposed guardrail.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.