

Ohio Department of Transportation Prebid Questions

Project No. 100230

Sale Date - 4/29/2010

Question Submitted: 4/23/2010

Question Number: 1

This question concerns reinforcing bar. Sheet 41/41 - Rear Abutment total should state 4306 lbs - Superstructure Mk
S502 - Wt should be 745 lbs Mk S503 - Wt should be 745 lbs Total wt adjustment Add 559 lbs

Addendum will be forthcoming.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.