

# Ohio Department of Transportation

## Prebid Questions

Project No. 060321

Sale Date - 7/12/2006

Question Submitted: 7/5/2006

Question Number: 1

Re. Ref. 64, Aggregate Base, APP. Is there a plan note describing whatever it is that warrants the APP designation?

Question Submitted: 7/6/2006

Question Number: 2

1) Re. REF. 180, INTERM. TP 2 PG64-28: There appears to be a bust in the quantity. Wearing Course Removed quan.= 358 SY on this bridge. This corresponds to a 1 1/2" surface quantity of 15 CY (Ref. 181). The 1 1/2" intermediate covers the same footprint but the bid quantity is 4 CY (Ref. 180). It looks like they included the approach slabs but left the bridge deck out of the calculation.

2) Re. REF. 129 TEMPORARY PAVEMENT: Plan quantity of 660 SY is incorrect. On Sheet 9E the Subsummary quantity of 495 SY should read 173 SY. On Sheet 9D the linear measurement of 165 LF was carried to the subsummary as 165 SY. It should read 55 SY. The total plan quantity should be 228 SY.

Question Submitted: 7/7/2006

Question Number: 3

ON BRIDGE STA-43-0089 THERE IS A BID ITEM FOR PILE ENCASEMENT- SHOULDN'T THERE ALSO BE AN ITEM FOR COFFERDAMS, CRIBS, AND SHEETING ?

ON BRIDGE STA-43-0304 SINCE THERE ARE SO MANY REPAIRS TO DO IN ONE DAY, HOW SHOULD WE MAINTAIN TRAFFIC ?- ARE TRAFFIC LIGHTS ACCEPTABLE ?

**A1) No, District 4 has sold tens of projects with this pay item and details and not included cofferdams, cribs and sheeting. There have not been any problems in construction performing this work. The bidders are directed to bid the plan as shown and include any incidental items necessary to complete the work. A2) District believes that the repairs are possible to complete in one day. Traffic should be maintained by MT-97.10**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.