

Ohio Department of Transportation

Prebid Questions

Project No. 050022

Sale Date - 1/12/2005

Question Submitted: 1/10/2005

Question Number: 1

Would 50" Portable Barrier Wall be acceptable in place of the 32" barrier with glare screen?

No, please use the barrier specified in the bidding documents.

Question Submitted: 1/10/2005

Question Number: 2

-Item 632 Vehicular signal Head, By Type Polycarbonate, APP

Under this item the specifications call out for the signals "as manufactured by Automatic Signal Control." All of the major signal manufacturers produce signals that meet & exceed ITE & IMSA sta

Because this question was submitted extremely late, an addendum including "or approved equal" cannot be issued without delay to the scheduled letting of this project. Because the dollar value of the 8 signal heads is relatively small compared to the entire cost of the project, we will not delay the sale of the project. Please prepare your bid based upon the bidding documents. However, requests to replace the proprietary items will be considered at the preconstruction conference.

Question Submitted: 1/5/2005

Question Number: 3

The single arm cantilever detailed in Elevation P-1 on plan sheet 55, ought to be reviewed to determine if a combination OHSS TC-12.30 is needed due to the two back-to-back 5-1/2 x 11' signs.

The Dept believes that the single arm cantilever design is adequate.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.