

# Ohio Department of Transportation

## Prebid Questions

Project No. 070014

Sale Date - 1/24/2007

Question Submitted: 1/19/2007

Question Number: 1

Page 3/16 - Curb Ramps" There are an estimated 32 sidewalk locations within the project limits requiring the installation of truncated domes." Is it ODOT's intention to cut out the existing sidewalk and replace with concrete base and truncated dome pavers? Is it acceptable to sawcut at 2' parallel to curb and remove and replace with brick pavers, base and finished sidewalk (boxing the pavers in at the sides with new concrete)?

**The assumption below is correct. Review sheets 6A, 6B and 6C for the location of the truncated domes, the truncated domes are placed at the back of the curb.**

Question Submitted: 1/19/2007

Question Number: 2

Page 3/16 - Curb Ramps" There are an estimated 32 sidewalk locations within the project limits requiring the installation of truncated domes." Is it ODOT's intention to cut out the existing sidewalk and replace with concrete base and truncated dome pavers? Is it acceptable to sawcut at 2' parallel to curb and remove and replace with brick pavers, base and finished sidewalk (boxing the pavers in at the sides with new concrete)?

**The assumption below is correct. Review sheets 6A, 6B and 6C for the location of the truncated domes, the truncated domes are placed at the back of the curb.**

Question Submitted: 12/28/2006

Question Number: 3

The above referenced project proposal contains line item Ref. 48 - Premium on Railroads Protective Liability and Property Damage Liability Insurance, 1 LS. Neither the plans or the proposal contain any information regarding the rail road owner, limits of insurance, daily number of trains, etc. This information will be required in order to price this item.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.