

# Ohio Department of Transportation

## Prebid Questions

Project No. 080591

Sale Date - 10/22/2008

Question Submitted: 10/21/2008

Question Number: 1

Bridges 261-0419,0457,0476 and 0494 has an existing 3" +or- concrete overlay. 1)Will the removal cost of the concrete be incidental to the Polymer Modified Asphalt Expansion Joint unit price bid. Page 17 the detail shows 5" of new asphalt replacement. That would make the Polymer Modified Expansion Joint 5"+or- not 3". Due to variable depths of asphalt. 2) Can these units of measure be changed from FT to CY. 3)Please clarify the locations of the item, Patching Concrete Structure, as per plan. If located on the bridge decks, Class S concrete requires a seven day cure time and maintaining traffic.

**Q.1 Will the removal cost of the concrete be incidental to the Polymer Modified Asphalt Expansion Joint unit price bid. Page 17 the detail shows 5" of new asphalt replacement. That would make the Polymer Modified Expansion Joint 5"+or- not 3". Due to variable depths of asphalt. A.1 There is no concrete to be removed in the placement of the Polymer Modified Expansion Joint (PMEJ). The PMEJ is to be cut into the asphalt after it is placed as per the plan detail. The depth of the PMEJ is to be 3". The bottom of the PMEJ will be at the top surface of the bridge deck concrete. There will be approx 2" of asphalt under the PMEJ on the Approach Slab side of the joint.Q.2 Can these units of measure be changed from FT to CY. A.2 The unit of measure will not be changed.Q.3 Please clarify the locations of the item, Patching Concrete Structure, as per plan. If located on the bridge decks, Class S concrete requires a seven day cure time and maintaining traffic.A.3 This item is not used on the top surface of the bridge decks. This is used on the abutments, wingwalls, piers, etc. The cure time will not have any effect on MOT.**

Question Submitted: 10/21/2008

Question Number: 2

Should Reference 7 be 4" Concrete walk as the plan states on page 5. The proposal & EBS file calls for 4" Asphalt Concrete walk.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.