

Ohio Department of Transportation

Prebid Questions

Project No. 062001

Sale Date - 2/15/2006

Question Submitted: 2/9/2006

Question Number: 1

Q1. The tender document does not specify a steel corrosion warranty. We recommend that the county amend the tender to include a steel corrosion warranty to read, 15 years full coverage against corrosion on all main truss components including end wall steel.

Q2. Does the roof fabric warranty also include equipment required to repair or replace the fabric.

Q3. Is ASTM A500, Grade C steel (structural grade), galvanizing after fabrication (post fabrication hot-dip galvanizing) according to ASTM A123 an acceptable equivalent to the Allied Gatorshield product specified in the tender.

A1): District feels an Exterior finish with a minimum corrosion of 2000 hours per salt spray test ASTM 117.0 along with the overall building warranty as stated in the plan to be sufficient. A2) No, labor for five years and the fabric for fifteen years as stated in the plan notes. A3) Has to meet the following to be equivalent: Exterior finish with a minimum corrosion of 2000 hours per salt spray test ASTM 117.0 has to be met as stated in the plans.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.