

Ohio Department of Transportation

Prebid Questions

Project No. 070122

Sale Date - 3/7/2007

Question Submitted: 2/26/2007

Question Number: 1

Will ODOT consider reducing the requirement that the bidder must perform 50% of the work for this project. With the amounts of specialty work on this project very few contractors can bid this project under this requirement.

Question Submitted: 3/1/2007

Question Number: 2

PLAN SHEET 7 OF 45 COLUMN 1 - NOTE #1 CALLS FOR A MINIMUM OF ONE ELEVEN FOOT LANE EACH DIRECTION DURING CONSTRUCTION. COLUMN 2 - 'PERMITTED LANE CLOSURE TIMES' INDICATES ONE LANE IN EACH DIRECTION 7 PM FRIDAY THROUGH 5 AM MONDAY FOR DRAINAGE AND WIDENING WORK. DOES THIS ALSO APPLY TO ELECTRICAL/TRAFFIC CONTROL WORK? IS IT THE INTENT TO COMPLETE THE PROJECT WITHOUT TAKING ANY LANES EXCEPT ON WEEKENDS?

A1) Yes - the permitted lane closure times apply to all work. A2) Yes - all lane closures are restricted to the permitted lane closure times; shoulders only may be closed at any time

Question Submitted: 3/2/2007

Question Number: 3

Page 37 of 45 in the plan set list the item " Loop Detector Unit, Delay and Extension Type" which does not appear as a pay item in the proposal. Will an addendum be issued to add this as a pay item to the project?

Per 633.18 payment for the loop detector units are included in the Item - Controller Unit, Type TS2/A2, with Cabinet, Type TS1.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.