

Ohio Department of Transportation

Prebid Questions

Project No. 090286

Sale Date - 5/20/2009

Question Submitted: 5/10/2009

Question Number: 1

Will the use of slag based products be allowed for use as 304 aggregate base and 703.11? Historically, the use of these products has been discouraged for use in this application.

Any material meeting the specs in the CMS will be permitted.

Question Submitted: 5/11/2009

Question Number: 2

where are the guardrail replacement items ?

There is only guardrail removal on this project. New guardrail installations will not be performed.

Question Submitted: 5/12/2009

Question Number: 3

Please add reinforcing steel pay items for the rebar in the head/wing walls. Currently there are no pay items for this work. Also, please add center line and edge line striping items to the proposal

The headwalls are to be constructed without reinforcing steel as per the details in the plan. Pavement striping will not be performed with this project.

Question Submitted: 5/12/2009

Question Number: 4

The existing pavement is indicated to be asphalt and reinforced concrete base per typical sections. The plans indicate that we are to remove pavement about 20 feet on either side of the new culverts. Under which bid does this work belong or does a pavement removed item need to be added?

Question Submitted: 5/12/2009

Question Number: 5

Where is the pay item for the Riprap using 6" Reinforced Concrete detailed on sheet 41 of 56?

Question Submitted: 5/6/2009

Question Number: 6

What would be the smallest or lightest roller that could be used for the asphalt portion of this project being each section is only 1320 sf.

Question Submitted: 5/8/2009

Question Number: 7

Can ODOT post the existing structure drawings online.

I placed the plans at \\ctrfs100\id04\$\Plans\TRU-77867

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.