

Ohio Department of Transportation

Prebid Questions

Project No. 060178

Sale Date - 3/22/2006

Question Submitted: 2/23/2006

Question Number: 1

On page 4/27 the plan gives the asphalt quantities for pav't restoration for pipe instalations. This note and these quantities do not match the sections shown for the LSM in the culvert drawings. (16/27 & 24/27)

These culvert replacements are a little more involved than a pipe crossing. These limits need to be extended a minimum of 25' to match the culvert and LSM cross section.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.