

# Ohio Department of Transportation

## Prebid Questions

Project No. 060101

Sale Date - 2/15/2006

Question Submitted: 2/8/2006

Question Number: 1

1. On page 4/53 the 'Maintaining of Traffic' notes neglect to specify the times route 77 can be closed per standard MT-99.60. We will be bidding accordingly.

2. Reference number thirteen requires 6 Special – Bollards. Please provide a drawing of these.

3. Reference number 12 Fence, Misc.: Wood Fence is bid per ODOT spec 607. No detail exists for the proposed fence along the abutment wing walls. Please provide clarification.

**A1. Notes 1,4 and 8 on SCD MT-99.60 address permitted closure times and duration of closure. A2. Bollard details and placement information are shown on SCD. A3. Fence (as per SCD RM-5.2) is shown between the proposed trail and proposed back of wingwall. Station and offset information is provided on the plan sheets (Sheets 7 and 8) showing beginning and end of fence.**

Question Submitted: 2/9/2006

Question Number: 2

1. Page 23/53 of the project plans shows a temporary sheeting line being driven near pier one. This sheeting line appears to run between the construction limits and therefore will limit access to pier one and the rear abutment for construction. Please provide details as to the need for this sheeting, how this is to be constructed, its location and final elevation.

**This sheeting is shown along the limits of the wetland area to minimize any impacts to the wetland as discussed in Note 2 on sheet 24/53. The depiction shown is only to provide a location for the sheeting if it is needed based upon the contractor's operation. The need for this sheeting, along with final elevation will be based upon the pier foundation excavation.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.