

# Ohio Department of Transportation

## Prebid Questions

Project No. 040414

Sale Date - 7/14/2004

Question Submitted: 10/23/2006

Question Number: 1

1. How will the power consumption for temporary lighting be paid?

2. manufacturer's warranties for equipment will expire one year afetr installation. Will ODOT accept equipment after installation? If not, how will the maintenance (and replacement if necessary) be paid until project completion.

Ambrish Bansal

Question Submitted: 7/22/2005

Question Number: 2

On sheet no 12/23 the plans state that Hydraulic Hoe Ram Hammers will not be permitted on the abutment removal. On past projects ODOT has allowed Hoe-Ram Hammers on the abutment removal, why did the department choose to not allow theses hammers. Will it be possible to utilize these hammers just on the abutment removal?

**The note referenced here is correct for this case. The abutment removal is backwall and portion of bridge seat. The abutments are on spread footings. No plan change is required.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.