

Ohio Department of Transportation

Prebid Questions

Project No. 050026

Sale Date - 1/12/2005

Question Submitted: 12/15/2004

Question Number: 1

Both of these projects are District #10 Micro-Surfacing.

Line #1 on both projects is Item #202 Wearing Course Removed. It calls for a 3/4 inch butt joint at ends of projects. Butt joints are normally not called for on Micro-Surfacing projects because of the ability to feather the material down so that there is nearly an imperceptible transition from old to new pavement. These butt joints would be necessary on a NovaChip or thin overlay but not with Micro-Surfacing. We would like to request that this item be omitted.

The District respectfully disagrees. No changes in the bidding documents will be made.

Question Submitted: 12/21/2004

Question Number: 2

It appears the answer for the question relating to project #28 got the answer which was supposed to go with project #31.

Thanks, Tim Amling

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.