

Ohio Department of Transportation Prebid Questions

Project No. 080281

Sale Date - 4/23/2008

Question Submitted: 4/1/2008

Question Number: 1

Reference Numbers 54, 55, 58. What type and grade of steel is to be used? What type of coating is to be applied?

For reference numbers 54 and 55, which is the steel piles are to be ASTM A992 Fy=50ksi steel. Reference number 58, which is the lagging supports can be ASTM A36 Fy=36ksi steel. There is to be no coating applied to the steel piles or lagging supports.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.