

Ohio Department of Transportation Prebid Questions

Project No. 050432

Sale Date - 7/27/2005

Question Submitted: 7/20/2005

Question Number: 1

In order to install the box culvert and new sanitary sewer line the existing sanitary sewer line will need to be shutdown. How long of a period will the existing 200mm be allowed to be out of service?

It can not be shot down. This sanitary main is owned by the Village of Dalton and it serves the whole east side of the village. The contractor must pump the line around the work area

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.