

Ohio Department of Transportation

Prebid Questions

Project No. 080648

Sale Date - 12/10/2008

Question Submitted: 3/17/2009

Question Number: 1

Ref 19 has a reinforcing mesh to be centered over a widening joint. Note this will place the product half on the new 301 and half on planed surface. Per manufactures recomendation, this Glasgrid product is to be placed on an " even surface." A milled surface will affect the bonding of this product and will not get you 100% contact of mesh with the planed surface.

We understand the manufacturers recommendations, but we feel that placing the fabric on the planed surface as per the plans is adequate. We have used this method with success on other projects and do not want to change the plans.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.