

Ohio Department of Transportation

Prebid Questions

Project No. 070429

Sale Date - 8/29/2007

Question Submitted: 8/24/2007

Question Number: 1

On Pgs. 31 & 40 @ Sta. 311+25 it states the existing 15" pipe is to be abandoned. There is no item for LSM or plugging the pipe. Is this to be an inclusive item to complete? Thank You

The plan reference to abandon the 15" pipe due to the removal of the catch basin shall be done by plugging or sealing the end of the pipe where the catch basin is removed. This is included with the catch basin removal.

Question Submitted: 8/6/2007

Question Number: 2

Would the Department consider increasing the amount allowed to be subcontracted on this project due to the numerous specialty areas, i.e. asphalt, electrical, guardrail, etc.?

The Dept respectfully declines to lower the WT percentage.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.