Ohio Department of Transportation - Prebid Questions

Project No. 100564 Sale Date - 11/18/2010

WIL-81001 - SR-34-15.55 (SERVICE ROAD)

Question Submitted:

10/12/2010 9:15:58 AM

Plans have cross sections - maintenance of traffic with cut elevations +/- 2 feet below existing grade. This removal is +/- 1 foot below new subgrade elevation. Is the propose of this to be an undercut and replacement with suitable embankment?

Line Item 0007 - Excavation 477 cy ... does this include the existing asphalt pavement?

Line Item 0009 - Embankment 821 cy ... does this include the topsoil?

The reason for the removal of the MOT is in order to maintain traffic during construction. Line Item 0007-Excavation-does not include existing asphalt pavement. It is included in Line Item 0002 Pavement Removed. Line Item 0009-Embankment-does not include topsoil. Topsoil is included in Line Item 0014 Topsoil.

*** DISCLAIMER - Prebid questions and answers provided are for informational purposes only and are not part of the Bid Documents. If a question warrants a clarification, the Department will issue an addendum addressing the request.

Thursday, October 21, 2010 4:25:25 PM Page 1