

Ohio Department of Transportation Prebid Questions

Project No. 100233

Sale Date - 4/29/2010

Question Submitted: 4/21/2010

Question Number: 1

For Bid Reference 0051 & 0059, you have three vendors listed on plan page 75/101, with a note OR ENGINEER APPROVED EQUAL. I would like to request Sternberg Lighting to be considered as an Approved Equal. Ref 0051 - Sternberg # 6216FP/3"x4"/GFI/DBBA/FH/55LPM/GRN Ref 0059 - Sternberg # G773/OLF/100MH480/MED/GRN Photometric Distribution G773-175MH[R].ies Specification sheets and photometric files are available on Sternberg's web site at: www.sternberglighting.com.

This pole and luminaire specified in the question will be considered an approved equal for this project.

Question Submitted: 4/26/2010

Question Number: 2

I cannot come up with ODOT's quantity for Ref #'s 112 and 113 can you give a better breakdown of your dimensions for these items. What does the As Per Plan Note pertain to for reference 113? Does ODOT know how deep the rebar in the sidewalk on Bridge NO WIL-15-0154 is? On page 7/101 there is a note in MOT notes that states contractor must remove pavement markings and include it in the MOT price. There is a pay item for pavement markings removed, so what exactly should we be including in the MOT item?

A1)Due to time restrictions we were unable to locate the bridge calculations for this item. The items were also broken out on sheet 22 of the plan. Please bid the quantities as shown.A2)The As Per Plan for reference 113 is shown on sheet 83, where the "box one" symbol refers to the area for the as per plan colored and stamped concrete surface on the inner 2'-0" of the walk.A3)The old plans give the depth of cover of the rebar in the sidewalk as one inch clear.A4)The conflicting pavement markings involved with the various MOT phases are to be included with the lump sum maintaining traffic item. The initial removal of the existing markings or any markings that may be relocated are included under the item 641 removal of pavement markings.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.