

Ohio Department of Transportation

Prebid Questions

Project No. 060348

Sale Date - 7/26/2006

Question Submitted: 7/5/2006

Question Number: 1

1. 6" water line will it be relocated by others? Can it be shut down? 2. Bldg on the east side has been taken down does this change anything? 3. Power lines on the west side of US 23 will they be moved out of the way? 4. Telephone lines on the east side when they are placed aurally will we have to work under them?

1. No., No, the contractor is to take precautions not to disturb the line during the excavation and placement of the culvert. 2. No. 3. Yes, as stated in the proposal utility note this is to be coordinated with the city for the relocation of the power pole. 4. Yes.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.