

Ohio Department of Transportation

Prebid Questions

Project No. 090188

Sale Date - 3/18/2009

Question Submitted: 12/30/2008

Question Number: 1

Plan sheet 2/7, note labeled "EXTRA AREAS" states in the last sentence that: 448 asphalt concrete quantities for drives, Mailboxes ect... are included in the extra area quantities. The same type note appears on plan sheet 4/7 right hand side: Mailbox, drives ect...quantities are included in the extra areas. The only bid item set up for 448 asphalt concrete is reference 9 with a quantity of 948 cy and this quantity only covers the main street paving area as shown in typical 1 & 2. There are no estimated or actual quantities detailed in the plans for these extra areas and not enough quantities set up in reference 9 to perform the extra areas. With the two extra area notes in the plans it seems the intention was to set up a bid item for extra areas but was left out.

These are standard plan notes included in our resurfacing projects. Since the pavement design for this project is grind and pave from curb to curb, there are no extra areas required so none included in the plans.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.