

Ohio Department of Transportation

Prebid Questions

Project No. 080126

Sale Date - 2/13/2008

Question Submitted: 2/7/2008

Question Number: 1

Ref; Tied Concrete Block Mat, Type 1, Plan Page 13 General Summary calls for 4.7 SY @ SLM 18.10, 18.13, 18.22, 23.43, & 23.51 The detail on page 6 shows a HW and Rock Channel Prot. Type C for these, no mat. which is correct.

The Tied Concrete Block Mat, Type 1 is used in conjunction with the Precast Reinforced Concrete Outlet for underdrain outlet pipes and the detail for the Tied Concrete Block Mat, Type 1 is in Standard Drawing DM-1.1, which is noted on the title sheet.

Question Submitted: 2/7/2008

Question Number: 2

BID ITEM FOR: Tied Concrete Block Mat, Type 1, did not find the detail, is there a standard drawing number?

The Tied Concrete Block Mat, Type 1 is used in conjunction with the Precast Reinforced Concrete Outlet for underdrain outlet pipes and the detail for the Tied Concrete Block Mat, Type 1 is in Standard Drawing DM-1.1, which is noted on the title sheet.

Question Submitted: 2/7/2008

Question Number: 3

Question#1: There appears to be errors in some of the dirt quantities. Please check. Examples can be found on sheets 22 and 39. Question#2: Because an excavation of approximately 10 feet in depth is indicated for most of the repairs, how is the contractor expected to hold the vertical face of the excavation without performing a longer more gradual cut into and then back out of the slope? Question#3: Some of the slide repairs are very narrow in width of treatment. One is actually only 20 feet long, when measured parallel with the roadway. This type of excavation would require additional excavation to allow equipment to perform the work. Will the required additional excavated material and subsequent replacement be subject to payment under the excavation and embankment quantities?

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.