

Ohio Department of Transportation Prebid Questions

Project No. 050589

Sale Date - 12/2/2005

Question Submitted: 11/28/2005

Question Number: 1

This question is for clarification only. Reference No. 17 60" Conduit, Type A, 707.03 and Reference No. 19 Conduit, Bored or Jacked: 60". According to the note on Sheet 2/13, it is our interpretation that Reference No. 17 is for the materials and installation of the 60" Conduit, Type A, 707.03 only. Reference No. 19 is for the materials and installation of the Steel Casing pipe and any other equipment and materials needed to install Reference No. 17. Is this interpretation correct?

Reference No. 19 - Item 603, CONDUIT, BORED OF JACKED: 60" CONDUIT, TYPE A, 707.03 is for the installation of the 60" CONDUIT, TYPE A, 707.03 by boring or jacking including providing the 0.50 INCH UNGALVANIZED CASING PIPE in accordance with Plan Note on Sheet 2 (Note that size of casing is not specified and is to be determined by the Contractor). Reference No. 17 - Item 603, 60" CONDUIT, TYPE A, 707.03 is for the cost of the 60" CONDUIT, TYPE A, 707.03 that is to be installed in the 0.50 INCH UNGALVANIZED CASING PIPE.

Question Submitted: 11/29/2005

Question Number: 2

It appears that Items #0017 60" Conduit, Type A, 707.03 and Item #0019 Conduit, Bored or Jacked: 60" Conduit, Type A 707.03 are payment for the same item. Is the intent to Bore & Jack a casing pipe larger than the 60" Conduit (ie 72" or 78" casing) and then install the 60" Conduit inside this casing?

Or is the intent to utilize a 60" casing pipe as part(80 Lin. Ft.) of the pipe run and, if so, can the 60" casing, with an I.D. of 59" be utilized for the entire 87 Lin. Ft.?

Reference No. 19 - Item 603, CONDUIT, BORED OF JACKED: 60" CONDUIT, TYPE A, 707.03 is for the installation of the 60" CONDUIT, TYPE A, 707.03 by boring or jacking including providing the 0.50 INCH UNGALVANIZED CASING PIPE in accordance with Plan Note on Sheet 2 (Note that size of casing is not specified and is to be determined by the Contractor). Reference No. 17 - Item 603, 60" CONDUIT, TYPE A, 707.03 is for the cost of the 60" CONDUIT, TYPE A, 707.03 that is to be installed in the 0.50 INCH UNGALVANIZED CASING PIPE.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.