

Ohio Department of Transportation - Prebid Questions

Project No. 120447

Sale Date - 7/12/2012

ADA-91248 - SR-125-1.25

Question Submitted: 7/5/2012 1:54:48 PM

Will you provide the full geotechnical report?

<ftp://ftp.dot.state.oh.us/pub/Districts/D09/P%26E/Beekman/ADA-125-0125>.

Question Submitted: 6/25/2012 3:34:55 PM

There is currently no pay item for the W18x119 Steel Beams located in the drilled shafts as shown on sheet 12 & 13. Will a pay item for the steel beams be added?

The W18x119 steel beams are paid for under Drilled Shafts, 30" Diameter, above Bedrock, as per plan and Drilled Shafts, 30" Diameter, into Bedrock, as per plan as described in the plans.