

Ohio Department of Transportation - Prebid Questions

Project No. 110539

Sale Date - 11/3/2011

ALL-87231 - VA-BP-FY2012

Question Submitted: 10/18/2011 3:03:45 PM

The odot website for allowable lane closure times on page 2 of the plans comes up as error when trying to open it. Can you please direct me to the right path to access this.

The permitted lane closure times are listed on the ODOT website at :

<http://plcm.dot.state.oh.us/>

Question Submitted: 10/13/2011 11:27:33 AM

We would like to obtain the existing structure drawings for the bridges on this project. Thank you.

<ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/D01-87231/>

Question Submitted: 10/4/2011 2:38:24 PM

Plans of existing bridges are on file at the District 1 office. Can they be made available electronically for contractors unable to view them at that office?

<ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/D01-87231/>

Question Submitted: 9/22/2011 5:00:30 PM

In our opinion, with the tight railroad vertical clearance of only 1' below the bottoms of the structures to work less the thickness of the work platform; we will not be able to paint the underside of the bottom flanges. We ask that ODOT exclude this from the contract.

See forthcoming addendum.

Question Submitted: 9/20/2011 4:40:21 PM

We need the existing vertical clearances provided from the top of the railroad tracks to the underside of the bridges.

The existing vertical clearance is 23'.