

Ohio Department of Transportation - Prebid Questions

Project No. 110548

Sale Date - 10/20/2011

ALL-87232 - VA-GR-FY2012

Question Submitted: 10/13/2011 1:47:24 PM

Under item 606E16501 Guardrail Rebuilt. The specification reads new or existing guardrail in good condition may be erected. Can I have a clarification on quantity of new guardrail that is expected for the project?

The general note for Guardrail Rebuilt, Type 5, As Per Plan allows the contractor the option of using new or usable salvaged materials. The contractor is responsible to determine if the sections of guardrail designated to be removed and replaced are damaged or are considered usable salvaged materials. No addenda required.

Question Submitted: 10/13/2011 11:38:13 AM

The plans do state the total number of guardrail panel that are to be rebuilt but the plans does not state the number of guardrail panels that are damaged. How many replacement guardrail panels are to be included in the bid item Guardrail rebuilt, type 5, as per plan?

The general note for Guardrail Rebuilt, Type 5, As Per Plan allows the contractor has the option of using new or usable salvaged materials. The contractor is responsible to determine if the sections of guardrail designated to be removed and replaced are damaged or are considered usable salvaged materials. No addenda required.

Question Submitted: 10/10/2011 8:54:50 AM

The guardrail rebuilt, type 5, as per plan note on sheet 2 of the plans states that damaged guardrail panels are to be replaced. Are these guardrail replacement panels included in the guardrail rebuilt, type 5, as per plan? How many panels are required?

- 1.) **Yes, see plan note for item on sheet 2 of 10.**
- 2.) **Refer to quantities provided in plans and reference Standard Construction Drawing GR-2.1 noted on Sheet 1 of 10 for additional details.**