

Ohio Department of Transportation - Prebid Questions

Project No. 160002

Sale Date - 1/14/2016

ALL-95274 - SR 309-10.22

Question Submitted: 1/11/2016 2:41:09 PM

How will the Inlets marked on the project for removal be paid. No 202 Inlet removal item has been established.

Question Submitted: 1/7/2016 11:26:53 AM

The conduit runs are small tie-ins and structures are replacement of existing in same locations. Will the state be waving the requirement of the 611.12 performance inspection?

The state will not revise the plan documents to waive the requirements of 611.12. Please refer to 611.12 for further details and direction.

Question Submitted: 1/7/2016 8:21:24 AM

Can cross sections of the Grand Avenue removal and restoration be released. It would help clarify what is to be required of removal depths, drainage grading, etc.

A forthcoming addendum with a sheet revision will address this question.

Question Submitted: 1/7/2016 8:17:35 AM

Page 3/46 shows a slope change in the roadway and in turn a top of curb change in the typical section. Can cross sections be released so we have enough information to bid the project. Also, if the curb and gutter is to be raised to change the road slope, how will the aggregate material placed beneath the gutter be paid?

The intended work will not require changes in the slope of the roadway. The proposed, roadway work will match the existing slope of the roadway. So, the replacement curb and gutter will not be raised. Bid the project per the plan documents.

Question Submitted: 12/22/2015 11:28:24 AM

Due to the large amount of electrical work and asphalt paving along with other miscellaneous items will ODOT consider lowering the prime work type percentage to 30% on this project?