

Ohio Department of Transportation - Prebid Questions

Project No. 151042

Sale Date - 7/30/2015

ALL-99984 - ALL Paving FS

Question Submitted: 7/24/2015 2:09:05 PM

The typical section on page 2 shows the proposed 1.5" Asphalt Surface Course finishing flush with the existing paved lot. Currently the existing aggregate base in the proposed lots is flush with the existing asphalt. There is no item in the project to excavate the existing aggregate base 6" and fine grade it for asphalt. Who will do this work and how will it be paid for? Also the edges of the existing asphalt are rolled down and cracked. They should be saw-cut back to a sound vertical face and tacked. Who will do this work and how will it be paid for?

The work being questioned will be completed by others. The project shall be bid according to the plan details and quantities. No addendum will be required.