

Ohio Department of Transportation Prebid Questions

Project No. 080516

Sale Date - 8/20/2008

Question Submitted: 8/12/2008

Question Number: 1

Your Completion Date is set for 6/30/2009. In the MOT notes (page 6 of 24) You have that we can't close the road for more than 30 days and can only occur from June 15,2009 to July 15,2009. This closure exceeds the completion date. Please Clarify

Question Submitted: 8/19/2008

Question Number: 2

Is there any by-pass pumping involved in this project.

Item 503, Cofferdams, cribs & Sheeting is provided for in the plans. This item covers any work required to dewater the excavation and protect the work. It is up to the contractor to decide what method he will use. Bypass pumping could be used if the contractor chooses to use it.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.