

Ohio Department of Transportation - Prebid Questions

Project No. 130403

Sale Date - 6/27/2013

ASD-76980 - IR-71-7.66 PM; WAY-71-0.00

Question Submitted: 6/22/2013 1:45:07 PM

Addendum No. 1 references Sheets 9A and 9B that were added by this addendum. Please make these sheets available.

Sheets 9A and 9B have been added. Please see the following FTP site link. <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/ASD-76980/>

Question Submitted: 6/13/2013 11:00:02 AM

Is light grinding still a permitted method for removal of the existing pavement markings?

Per 614.11G-1a of CMS, the use of grinding is not allowed to remove existing pavement markings on microsurfacing projects.

Question Submitted: 6/7/2013 11:03:16 AM

Could more information be provided for Ref. 1, 251 Partial Depth Pavement Repair? In particular, the approximate locations of the repairs would be useful. Given that this job is spread over 90 lane miles, it is difficult to determine appropriate pricing without more information. Thank you.

The District will provide more information on approximate locations of the repairs by the end of this week.