

Ohio Department of Transportation Prebid Questions

Project No. 100058

Sale Date - 2/4/2010

Question Submitted: 1/21/2010

Question Number: 1

Power Service, as per plan "B" requires that all fees associated with the installation and hookup of the power service by NCEC shall be paid by the contractor. Has there been a set fee or estimate from NCEC established for this work? We request that ODOT include an allowance for this cost, or allow reimbursement to the contractor for the costs if the costs are unknown.

Contractor should contact North-Central Electric Co-Op (NCEC) to determine what fees, if any, are required. Contact information for NCEC is provided on sheet 5 in plan. No reimbursement or allowance for this cost shall be provided by ODOT per the general note

Question Submitted: 1/26/2010

Question Number: 2

Bid reference # 21 , School Speed Limit Sign Assembly, 36" x 60" As Per Plan requires an incandescent center section but does not specifies the illuminating source for the beacons. Are the school sign beacons to also be incandescent or LED?

The school flasher beacons should be incandescent.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.