

# Ohio Department of Transportation - Prebid Questions

Project No. 150102

Sale Date - 3/5/2015

ASD-88811 - SR 511-14.07

*Question Submitted:* 2/23/2015 11:14:13 AM

The bar material specified, 1.25"\*2" is not available. Three warehouses have been contacted. There is not enough material to go mill direct. Can 1.5\*2 be used? If so will the plan quantity be revised?

**This request has been reviewed. Please bid as per the plans.**

*Question Submitted:* 2/20/2015 4:14:26 PM

The Expansion joint modification on sheet has been specified as Level UF. This work has always been bid as Item 516, not Item 513. In addition, the note for the Level UF on sheet 27/48 states "...submit a stamped drawing". If bid as Item 516, P.E. stamping of drawings is not required. Please clarify.

**This type of repair has been bid as Item 513 on previous District 3 projects. Bids should be prepared as per the plans.**