

# Ohio Department of Transportation - Prebid Questions

Project No. 160524

Sale Date - 10/6/2016

ATB-100318 - SR 84-0.00/3.85

Question Submitted: 10/5/2016 9:44:12 AM

On Items 611,623 & 638 are you allowed to use risers to adjust existing catch basin, manholes, monument boxes and valve boxes on this project?

**Yes, risers are acceptable.**